

LEAD IS PRESENT SO I CANT SIGN THE RIDER



EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018
Phone/Fax: (212) 290-0051 / (212) 290-0058
http://www.EMSL.com manhattanlab@emsl.com

EMSL Order: 031606362
CustomerID: NYHM25
CustomerPO: 81620141404025
ProjectID: EHSA-14-9526-N0

Attn: **New York City DOH & Mental Hygiene
LPPP - Field Support Unit
125 Worth Street, 6th Floor CN58
New York, NY 10013**

Phone: (646) 632-6002
Fax:
Received: 03/09/16 11:54 AM
Collected: 3/4/2016

Project: LASU# L2016-0204/ 235 EAST 5TH STREET/ APT: CMN/ BORO: MANHATTAN/ HEALTH AREA: 146500

Test Report: Lead in Dust by Flame AAS (SW 846 3050B/7000B)*

Client Sample Description	Lab ID	Collected	Analyzed	Area Sampled	Lead Concentration
030416-1477-001 Site: BUILDING FOYER FROM STREET Desc: FLOOR/ NO WINDOW/ CERAMIC	031606362-0001	3/4/2016	3/9/2016	144 in ²	34 µg/ft ²
030416-1477-002 Site: 1ST FLOOR PUBLIC HALLWAY FROM BUILDING FOYER Desc: FLOOR/ NO WINDOW/ CERAMIC	031606362-0002	3/4/2016	3/9/2016	144 in ²	110 µg/ft ²
030416-1477-003 Site: STAIRS FROM 1-2 FLOOR PUBLIC HALLWAY Desc: TREAD/ NO WINDOW/ LINOLEUM	031606362-0003	3/4/2016	3/9/2016	297 in ²	33 µg/ft ²
030416-1477-004 Site: 2ND FLOOR PUBLIC HALLWAY FROM STAIRS Desc: FLOOR/ NO WINDOW/ LINOLEUM	031606362-0004	3/4/2016	3/9/2016	144 in ²	37 µg/ft ²
030416-1477-005 Site: STAIRS FROM 2-3 FLOOR PUBLIC HALLWAY Desc: TREAD/ NO WINDOW/ LINOLEUM	031606362-0005	3/4/2016	3/9/2016	297 in ²	19 µg/ft ²
030416-1477-006 Site: 3RD FLOOR PUBLIC HALLWAY FROM STAIRS Desc: FLOOR/ NO WINDOW/ LINOLEUM	031606362-0006	3/4/2016	3/9/2016	144 in ²	38 µg/ft ²
030416-1477-007 Site: STAIRS FROM 3-4 FLOOR PUBLIC HALLWAY Desc: TREAD/ NO WINDOW/ LINOLEUM	031606362-0007	3/4/2016	3/9/2016	297 in ²	24 µg/ft ²
030416-1477-008 Site: 4TH FLOOR PUBLIC HALLWAY FROM STAIRS Desc: FLOOR/ NO WINDOW/ LINOLEUM	031606362-0008	3/4/2016	3/9/2016	144 in ²	28 µg/ft ²
030416-1477-009 Site: STAIRS FROM 4-5 FLOOR PUBLIC HALLWAY Desc: TREAD/ NO WINDOW/ LINOLEUM	031606362-0009	3/4/2016	3/9/2016	297 in ²	18 µg/ft ²
030416-1477-010 Site: 5TH FLOOR PUBLIC HALLWAY FROM STAIRS Desc: FLOOR/ NO WINDOW/ LINOLEUM	031606362-0010	3/4/2016	3/9/2016	144 in ²	24 µg/ft ²
030416-1477-011 Site: STAIRS FROM 5TH FLOOR TO ROOF Desc: TREAD/ NO WINDOW/ LINOLEUM	031606362-0011	3/4/2016	3/9/2016	324 in ²	11 µg/ft ²

M. Apfeldorfer

Miron Apfeldorfer, Laboratory Manager
or other approved signatory

Reporting limit is 10 µg/wipe. The QC data associated with these sample results included in this report meet the method quality control requirements, unless specifically indicated otherwise. Unless noted, results in this report are not blank corrected. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities.

* slight modifications to methods applied Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted Samples analyzed by EMSL Analytical, Inc. New York, NY AIHA-LAP, LLC--ELLAP Accredited #102581, NYS ELAP 11506

Initial report from 03/10/2016 08:00:26



EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018
Phone/Fax: (212) 290-0051 / (212) 290-0058
<http://www.EMSL.com> manhattanlab@emsl.com

EMSL Order: 031606362
CustomerID: NYHM25
CustomerPO: 81620141404025
ProjectID: EHSA-14-9526-N0

Attn: **New York City DOH & Mental Hygiene**
LPPP - Field Support Unit
125 Worth Street, 6th Floor CN58
New York, NY 10013

Phone: (646) 632-6002
Fax:
Received: 03/09/16 11:54 AM
Collected: 3/4/2016

Project: LASU# L2016-0204/ 235 EAST 5TH STREET/ APT: CMN/ BORO: MANHATTAN/ HEALTH AREA: 146500

Test Report: Lead in Dust by Flame AAS (SW 846 3050B/7000B)*

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Area Sampled</i>	<i>Lead Concentration</i>
030416-1477-012	031606362-0012	3/4/2016	3/9/2016	n/a	<10 µg/wipe
Site: BLANK					

M. Apfeldorfer

Miron Apfeldorfer, Laboratory Manager
or other approved signatory

Reporting limit is 10 ug/wipe. The QC data associated with these sample results included in this report meet the method quality control requirements, unless specifically indicated otherwise. Unless noted, results in this report are not blank corrected. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities.

* slight modifications to methods applied Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted
Samples analyzed by EMSL Analytical, Inc. New York, NY AIHA-LAP, LLC--ELLAP Accredited #102581, NYS ELAP 11506

Initial report from 03/10/2016 08:00:26